


PIER -Environmental Area



Avian ResearchProgramTransmission-Distribution Line Issues

Linda Spiegel June 28, 2005

Distribution and Transmission System Cause Electrocutions and Collisions




- Electrocutions on poles when birds contact energized phase to phase or energized phase to ground components
 - May result in outage
 - > 6.5 Million distribution poles in California
- Collisions with conductors

Often undetected

 ~32 k miles of transmission line in California



Costs to birds and utilities



- Extent of Fatalities
 Unknown ~ 1000's/yr
- No Standardized Reporting Requirements
- 25% Outages (PG&E)
- 1/3 Maintenance Costs
- Mitigation is pole specific–time/costs




Research Needs



- Risk Assessment
- Risk Reduction
- Monitoring
- Technology Transfer



Study w/PG&E to Evaluate Retrofitting



Homemade Triangular Perch Guard Installed on Wrong Side of Upper Crossarm

- 15% Degraded
- 65% Installed incorrectly



Bushing Cover Installed Above the Bushing-Mounted Cutout



Risk Assessment and Risk Reduction



Distribution System


- Evaluate Effectiveness of Retrofitting - USGS
- Risk Predictive Models -PG&E/SCE
- Effectiveness of Flight
 Diverters CSU Sac





Testing durability of diverters

- Evaluate effect of
 Corona voltage is raised
 so the surrounding air is
 ionized and conductive
- Sharp corners and uneven surfaces can be source of corona emission
- All generated corona at 230 kV
- Only one device damaged
- Non-swing type had no detected corona






Technology to Reduce Time/Costs

Bird Strike Indicator

- Automated devise to record bird strikes in field
- EPRI, WAPA,Utilities, EDMInternational, Inc



Bird Strike Monitor



Technology Transfer

SUGGESTED PRACTICES FOR RAPTOR PROTECTION ON POWER LINES: THE STATE OF THE ART IN 1996



Revising and Updating "Suggested Practices for Raptor Protection on Powerlines: The State of the Art in 1996"











Technology Transfer



Bird Electrocution
 Mitigation Web Site
 and Product
 Encyclopedia – EDM,
 International, Inc





Home

Problem Configurations

Product Selector

Feedback

Logout

Product Effectiveness

The following is a list of measures employed by utilities to mitigate distribution overhead animal contacts. The table results are based on a utility survey. Each utility reviewed the list and graded the effectiveness of each measure applying the following grades: A. Excellent B. Very Good C. Good D. Poor F. Failed

Utilities also graded their satisfaction with each product's long-term durability. The table provides a tabulation of the number of utilities employing each measure and an averaged grade.


It is important to note these utility rankings are for a class of product (e.g., bushing covers, conductor guards, perch guards, etc.) and **NOT** for specific vendor products. This section will be updated as utilities provide additional feedback.

Ranking of Mitigating Measures used on Distribution Overhead Facilities.

Mitigating Measures to Reduce Animal Contacts	No. Utilities	Mitigation Success	Long-Term Durability
		ABCDF	ABCDF
Insulating Measures			
Wood/Fiberglass Insulated Equipment Mounts	17	В	В
Bushing Covers	54	В	С
Insulated Jumper/Stinger Wires	47	В	В
Insulated Primary Wire	11	В	В
Heat-Shrink Insulation Material	10	В	В
Insulating Tape	12	В	C
Insulating Paint	2	В	В
Insulating Spray	1	С	С
Stirrup Covers	2	В	В




Technology Tranfer




"Raptor Mortality Field Guide" – EDM International, Inc



Avian Collision Not Well Studied





- Nationally ~ unknown
- CA, unknown
 - Mare Island: 313/mi/yr
 - 5K miles lines in CV
 - 5.5M wintering ,8K breeding waterfowl
 - potential 300K/yr



Thank you!

Linda Spiegel

Lspiegel@energy.state.ca.us

(916) 654 4703